

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161180, Building Permit - Commercial

Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT,
MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Not Ready	Tuesday, April 11, 2017

Partial Correction

1	THE FOLLOWING AREAS ARE APPROVED	1st floor north side. south side ok
---	-------------------------------------	--

Partial Correction

2	THE FOLLOWING AREAS ARE APPROVED	OK TO COVER WHEN READY UNDER-SLAB SANITARY WASTE LINES AT PARKING GARAGE COMPLETE AND EXTENDED TO OUTSIDE SW BLDG LINE
---	-------------------------------------	--

Partial Correction

3	THE FOLLOWING AREAS ARE APPROVED	OK TO COVER WHEN READY UNDER-SLAB STORM DRAIN PIPING FROM (4) SOUTH TO (6.5) AND EXTENDED TO OUTSIDE SW BLDG LINE;
---	-------------------------------------	--

Corrective Action Required

4	P3005 DRAINAGE SYSTEM	PERMIT PRINTS ARE DATED 10/10/16. CONTRACTOR'S WORKING SET IS REVISED THROUGH FEB 2017. NOT APPROVED TO COVER.
---	-----------------------	---

Comments: