

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20161027, Public Works Infrastructure Permit - Commercial
TWIN LAKES INSURANCE
Address: 2641 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

| Inspection: | Inspector: | Outcome: | Date: |
|---|-------------------|-----------------|----------------------------|
| PW-Sanitary Sewer Construction Inspection Informational | Tom Chandler | Passed | Tuesday, April 11, 2017 |

- 1 Sanitary sewer stub was located at approximately 120ft. from existing manhole. Contractor tied into stub and ran lateral service line to the building. (2) clean outs were installed according to plans.

Comments: