

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

April 12, 2017

KLOVER ARCHITECTS
10955 LOWELL AVE, SUITE 700
OVERLAND PARK, KS 66210

Permit No: PRCOM20171075
Project Title: MAZUMA CREDIT UNION - INTERIOR ALTERATIONS
Project Address: 1155 NE DOUGLAS ST, LEES SUMMIT, MO 64086
Parcel Number: 52910150600000000
Location: MAPLE TREE PLAZA 2ND PLAT---LOT 5 (EX PT IN ROW)
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: BUSINESS
Description: INTERIOR ALTERATIONS TO BANK

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.

Planning and Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Licensed Contractors

Reviewed By: Joe Frogge

Rejected

1. Lee's Summit Code of Ordinance, Section 7-130.10 - Business License. It shall be unlawful for any person to engage in the construction contracting business without first obtaining a business license as required under the applicable provisions of Chapter 28 of the Lee's Summit Code of Ordinances.

Action required: Either a Class A or Class B license is required. Provide the name of the licensed general contractor.

2. Lee's Summit Code of Ordinance, Section 7-130.4 - Business License. (excerpt)

No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed MEP contractors.

Building Plan Review

Reviewed By: Joe Frogge

Rejected

1. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes.

CODES ADMINISTRATION**2. Unified Development Ordinance Article 7, Section 7.180.E**

Roof mounted equipment – All roof-mounted equipment shall be screened entirely from view by using parapet walls at the same height as the mechanical units. For additions to existing buildings that do not meet this standard, individual screens will be permitted, with the design subject to approval by the Director.

Action required: Make needed corrections to drawings that provide details as to how mechanical equipment (MCU-1) will be screened per referenced UDO section.

3. 2012 IBC 1109.12.3 – Point of sale and service counters. Where counters are provided for sales or distribution of goods or services, at least one of each type provided shall be accessible. Where such counters are dispersed throughout the building or facility, accessible counters shall also be dispersed.

Action required: Modify Back Teller Station to provide minimum 36" of accessible space at maximum 36" high.

4. Section 7.330. CPTED Review Requirement.

All development applications shall be subject to CPTED review and recommendations. The application of CPTED concepts and strategies is site specific and the level of review shall be determined on a case by case basis. Some requests during development review will require mandatory compliance. Others will be strongly encouraged but compliance will be voluntary. Mandatory compliance elements will be addressed in Article 9 "Uses with Conditions".

Section 7.340. CPTED Uses Specified The following uses have been classified as "Uses with Conditions" per Article 9 of this Chapter, having been determined with a tendency toward an increased risk of crime,. Specific conditions for such uses are found in Article 9 and shall be required to be met prior to receiving any zoning approval, business license or approval to occupy any commercial space.

1. Bank/Financial Services
2. Bank Drive-Thru Facility
3. Check Cashing and Payday Loan Business
4. Convenience Store (C-Store)
5. Financial Services with Drive-up Window or Drive-Thru Facility
6. Pawn Shop
7. Title Loan Business, if performing on site cash transactions with \$500 or more in cash on hand
8. Unattended self-serve gas pumps
9. Unsecured Loan Business
10. Other similar uses shall meet the same standards as the above

Action required: Submit drawings or detailed report/spec to demonstrate compliance. A separate review for CPTED requirements must be performed. Permit will not be issued until CPTED review is approved.

Fire Plan Review**Reviewed By: Joe Dir****Approved with Conditions**

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED: (verified at inspection)

Post the numeric address of 1155 on the building in a contrasting color to the background. Address shall be readable from the roadway (Douglas St.)

CODES ADMINISTRATION

2. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED: (verified at inspection)

Provide a minimum of two 2A-10BC fire extinguishers. (rating 5 pound)

3. 2012 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

ACTION REQUIRED: (verified at inspection)

Mount the fire extinguishers on a normal path of travel close to an exit. The travel distance to an extinguisher shall be a maximum distance of 75 feet from anywhere within the business.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.