

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20162363, Building Permit - Commercial
Address: 805 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Wednesday, April 12, 2017

Partial Correction
1 Misc

OK TO POUR WHEN READY PERIMETER FOOTING & INTEGRAL COLUMN FOOTINGS AT N, E, & S. NO UFER JUMPERS INSTALLED IN THESE SECTIONS.

12/30-OK THE ELEVATOR SLAB

Partial Correction
2 Misc

OK TO POUR POST-TENSIONED FLOOR SLAB SYSTEM AS APPROVED BY SPECIAL INSPECTOR.

Partial Correction
3 Misc

OK TO POUR WHEN READY RETAINING WALL FOOTINGS AT SW & NW

Partial Correction
4 Misc

OK TO POUR WHEN READY TRENCH FOOTINGS AT BOTH DETACHED GARAGES. ENSURE MIN 3" RE-BAR CLEARANCE TO BOTTOMS AND BANKS DURING POUR.

Comments: