

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit: PRRES20162246, Building Permit - Residential
Address: 1333 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed.

| | | | |
|----------------------------|------------|--------------|---------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Driveway Inspection | Bart Reese | Forms Passed | Wednesday, April 12, 2017 |

Comments: Cross graident/cross slope must be <2% on the sidewalk and on the sidewalk path through the driveway. Checked the forms, which looked okay. Must check the cross-gradient of the sidewalk when concrete sets up to verify compliance: cross gradient <2%.