PLANNING AND CODES ADMINISTRATION DEPARTMENT 220 SE GREEN STREET LEE'S SUMMIT, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20162545, Building Permit - Residential Address: 1357 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Khanh Nguyen Failed Thursday, April 13, 2017

Codes Residential

Corrective Action Required

L Misc -FINAL GRADE, SOD, SPLASHBLOCKS

-EXPOSE AND BRING TO FINAL GRADE THE WATER METER

-SEWER TRACER BOX

-SEAL EXTERIOR: EXT. WALL PENETRATIONS, LIGHTS, ABOVE

METER AND AC DISCONNECT

-INSTALL SUMP PUMP BACKUP BATTERY

-BLOCK BASEMENT DOOR STUD PER SECURITY CODE; INSTALL

4-3' SCREWS AT STRIKE PLATE

-OPEN CEILING ELECTRICAL BOX NEAR FURNACE

-NO POWER TO BASEMENT LIGHTS AND RECEPTACLES

-DECK EXTERIOR DOOR: INSTALL 4-3' SCREWS AT STRIKE PLATE

-INSTALL WATER HAMMERING ARRESTORS FOR DISH WASHER

AND CLOTHES WASHER

-INSTALL FACE PLATE FOR THE RECEPTACLE INSIDE THE MUD

CLOSET

-FIREBLOCK THE BASEMENT FROM GARAGE AT BEAM POCKET
-THE FRONT NORTH BED SMOKE ALARM NOT INTERCONNECTED

-INSTALL BEDROOM WINDOW CRANKS

Comments: