

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20170898, Building Permit - Commercial
Address: 196 NW OLDHAM PKWY, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mark Harding	Failed	Thursday, April 13, 2017

Corrective Action Required

1	Misc	- uncover 5 outlet boxes in wall from box to ceiling or horizontal to next box. - remove ceiling tile for inspection of electrical going into wall.
---	------	--

Comments: