

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mike Copeland	Partial	Thursday, April 13, 2017

Partial Correction

1	Misc	OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING 2ND FLOOR LOCATIONS: A218; C271; AREA "A"; AREA "C" N OF STAIR; C202; C203; C206; C207; B209; B258A; C218; C205; 202; 203; AREA "D": B257; B257A; B257B; B258; B261; ALL NORTH OF (G) EXCEPT 254, 256, 257; BETWEEN COMMONS A-C EXCEPT 202,3,6,9,18.
---	------	--

Partial Correction

2	Misc	OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING 1ST FLOOR LOCATIONS: EAST WALL OF ELECT 3-161; OK TO 4' TOP-OUT WALLS; AREA "A" COMPLETE AREA "B": B101 S,W,N WALLS; B102; 103; 104; 105; 106; 107; 108; 109; 110; 111; 152; 153; 153A; 153B; 154; 155; 156-161; AREA "C" COMPLETE EXCEPT C160; B153; D161; B209; B258A; AREA "D": D150/151/152 NORTH & WEST WALLS; 150A; 151A; 152A; 153; 154; 155; 159; 160; 162; D156; D157; D102; D103; 4-151A, D154A, D154B FULL HEIGHT; D101; B150 N&E; B151 N&W;
---	------	--

*: EAST WALL TO 12' AFF ONLY

Partial Correction

3 Misc

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING
+ IN-WALL SYSTEMS AT FOLLOWING MEZZANINE LOCATIONS:
301 WEST WALL;

SOFFITS IN BETWEEN 202 AND 203 AND IN THE BATHROOMS
APPROVED.
A200 APPROVED

NO VIOLATIONS IN WALL D257 AND 256, NEED TO FIRECAULK
ELECTRICAL PENETRATIONS IN THE SHAFT WALL.

APPROVED TO COVER: B260, B259, B253, B254

Comments: