

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162811, Building Permit - Commercial  
Address: 860 NW BLUE PKWY, Unit:W, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mike Copeland	Partial	Thursday, April 13, 2017

Partial Correction  
1 Misc

OK TO COVER WHEN READY GWB CEILING / SOFFIT FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: CEILING AT BAR AREA; BULKHEADS AT DINING AREA EAST AND ENTRANCE SOUTH; HARD LID CEILING ABOVE THE BAR AREA; VESTIBULE 101; PLATFORM DINING AREA 103; DINING AREA 107; DINING AREA 108; CORRIDOR 118; OFFICE 116; MEN'S RR 117; WOMEN'S RR 118;

KITCHEN AREA: RE-ESTABLISH 1 HOUR RATING WALL AT WEST WALL WHERE 1 HOUR WALL WAS DEMO.  
OKAY TO DROP THE REST OF THE KITCHEN.

<b>Hood/Duct Inspection</b>	Mike Copeland	Passed	Thursday, April 13, 2017
-----------------------------	---------------	--------	--------------------------

**Comments: 2ND LAYER OF HOOD WRAP APPROVED**