

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162048, Building Permit - Commercial  
Address: 820 NW BLUE PKWY, Unit:H, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mike Copeland	Partial	Thursday, April 13, 2017

Partial Correction  
1 Misc

OK TO COVER WHEN READY LIGHT-GAUGE STEEL FRAMING FOR SOFFITS/BULKHEADS AT: MEN'S APPAREL 001;

LIGHT COVES AT MEN'S H&M, LADIES EAST OF (C);

Partial Correction  
2 Misc

OKAY TO COVER ABOVE CEILING IN THE BABY/BOY/GIRL FLOOR AREA

<b>In-wall Inspection</b>	Mike Copeland	Partial	Thursday, April 13, 2017
---------------------------	---------------	---------	--------------------------

Partial Correction  
1 Misc

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES: BOYS/GIRLS APPAREL EXCEPT ABOVE TWO FRAMED OPENINGS AT NORTH AND WEST; 012; 015; 016; 018 E/S/W WALLS; 019; 022; MEN'S APPAREL 001; POSTER WINDOW; LADIES 001 EXCEPT AT NW CORNER ENTRANCE AREA; 011; 012; 013; LOUNGE/ MGR OFC N WALLS; CORRIDOR CROSSWALL @ DOOR 109; POSTER WINDOW #3; FITTING 022; FITTING 008;

DOOR FRAMES AND POSTER DISPLAY FRAMING APPROVED.

**Comments:**