

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20170898, Building Permit - Commercial  
Address: 196 NW OLDHAM PKWY, Unit:A, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Mark Harding	Failed	Friday, April 14, 2017

### Corrective Action Required

1	Misc	- 4 outlet boxes at the center wall need equipment grounding conductors.
		- leave some of the ceiling tiles out for inspection of securing the MC cable to the new boxes.
		ok to cover the wall.
		if device is installed leave out for inspection of EG.

### Comments: