



**LEE'S SUMMIT**  
**MISSOURI**



**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No: PRCOM20161750 Date: April 17, 2017  
Project Title: SUMMIT SQUARE - BUILDING #1 Applicant:  
Location: 783 NW DONOVAN RD, LEES RANGER FIRE INC  
SUMMIT, MO 64086 1000 S MAIN ST STE 150  
GRAPEVINE, TX 76051  
Type of Work:  
Occupancy Group: R-2  
Description: NEW 4 STORY APARTMENT BUILDING Primary: (817) 410-9070  
REF: PRCOM20162361 FOR  
FOUNDATION PERMIT  
Construction Type: Type VA (1 hour)  
Map Page: 195B

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Sprinkler Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

**ACTION REQUIRED:**

Field tests and acceptance testing of the systems will be required prior to the final occupancy inspection. To schedule a test contact the fire department at 816-969-1300.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**