



# LEE'S SUMMIT MISSOURI



## FIRE DEPARTMENT

### PLANS REVIEW CONDITIONS

Permit No:	PRCOM20170233	Date:	April 17, 2017
Project Title:	AMAZING LASH STUDIO	Applicant:	
Location:	930 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086	ABSOLUTE FIRE INC 13906 CENTURY LN GRANDVIEW, MO 64030	
Type of Work:			
Occupancy Group:			
Description:	TENANT FINISH FOR EYELASH EXTENSION SERVICE	Primary: (816) 737-9991	
Construction Type:	Type IIB (Unprotected)		
Map Page:	195A		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Sprinkler Plan Review**

**Reviewed By: Jim Eden**

**Released for Construction**

**1. ACTION REQUIRED: (verified at inspection)**

All flow swithces, tamper valves for this suites system shall be clearly marked with the suites address and readable from floor level.

2. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

**ACTION REQUIRED: (verified at inspection)**

The systems riser shall be current with all required service and maintenance. A current tag shall be posted on the systems riser.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**