

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Monday, April 17, 2017

Partial Correction

1 Misc

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING
+ IN-WALL SYSTEMS AT FOLLOWING 2ND FLOOR LOCATIONS:
A218; C271; AREA "A"; AREA "C" N OF STAIR; C202; C203; C206;
C207; B209; B258A; C218; C205; 202; 203;

AREA "D": B257; B257A; B257B; B258; B261; ALL NORTH OF (G)
INCLUDING 254, 256, 257;

BETWEEN COMMONS A-C EXCEPT 202,3,6,9,18.

Partial Correction

2 Misc

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING
+ IN-WALL SYSTEMS AT FOLLOWING 1ST FLOOR LOCATIONS: EAST
WALL OF ELECT 3-161; OK TO 4' TOP-OUT WALLS;

AREA "A" COMPLETE

AREA "B": B101 S,W,N WALLS; B102; 103; 104; 105; 106; 107; 108;
109; 110; 111; 152; 153; 153A; 153B; 154; 155; 156-161;

AREA "C" COMPLETE EXCEPT C160; B153; D161; B209; B258A;

AREA "D": D150/151/152 NORTH & WEST WALLS; 150A; 151A;
152A; 153; 154; 155; 159; 160; 162; D156; D157; D102; D103;
4-151A, D154A, D154B FULL HEIGHT; D101; B150 N&E; B151
N&W;

*: EAST WALL TO 12' AFF ONLY

Partial Correction

3	Misc	OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING MEZZANINE LOCATIONS: 301 WEST WALL; SOFFITS IN BETWEEN 202 AND 203 AND IN THE BATHROOMS APPROVED. A200 APPROVED NO VIOLATIONS IN WALL D257 AND 256, NEED TO FIRECAULK ELECTRICAL PENETRATIONS IN THE SHAFT WALL. APPROVED TO COVER: B260, B259, B253, B254
---	------	---

Rated Assembly Inspection

John Borns

Partial

Monday, April 17, 2017

Partial Correction

1 Misc

PARAPET BEWEEN AC SECTIONS AND BD, MINERAL WOOL AND FIRE PROOFING BETWEEN SHAFT WALLS APPROVED.

Partial Correction

2 Misc

SEPARATION WALL ON (6):
INNER WYTHe: PENETRATIONS OF LINER BOARD FIRE-STOPPED;
OK TO HANG 5/8" TYPE X GWB BOTH FACES;

OUTER WYTHe: 1ST FLOOR FROM N TO R WEST FACE;

OUTER WYTHe: 2ND FLOOR FROM J TO N WEST FACE;

WEST FINISH FACE: OK TO HANG 1ST LAYER TO 12' AFF FROM B TO

**WEST FINISH FACE: LEVEL ONE 1ST LAYER APPROVED FULL HEIGHT FROM (A) TO (BB);
LEVEL TWO OK FOR 1ST LAYER FROM (A) TO (G);**

EAST FINISH FACE OK TO HANG ONE LAYER FULL HEIGHT FROM NEAR A TO BB

Partial Correction

3 Misc

ELEVATOR SHAFT -- OK TO COVER WHEN READY: FRAMING + LINER BOARD FULL HEIGHT NORTH, EAST, SOUTH WALLS; EAST WALL 2ND FLOOR 1ST LAYER 5/8" TYPE X; 1ST FLOOR S WALL OK TO HANG 2ND LAYER 5/8" TYPE X GWB; 1ST FLOOR N WALL OK TO HANG BOTH LAYERS 5/8" TYPE X GWB; 2ND FLOOR OK FOR 2ND LAYER 5/8" TYPE X AT N,E,S WALLS; **ELEVATOR FRONTS AT LEVEL ON AND LEVEL TWO FRAMING & LINER BOARD OK FOR 5/8" TYPE X ON LOBBY FACE;**

Partial Correction

4	Misc	AT ELEVATOR EQUIPMENT ROOM A150 OK TO APPLY 1ST LAYER 5/8" TYPE X GWB AT WEST WALL, 2 LAYERS AT CONNECTION WITH INTERSECTING WALL; 2ND LAYER 5/8" TYPE X GWB AT WEST WALL; FRAMING + ONE LAYER 1" LINER BOARD AT CEILING; SOUTH WALL OK TO COVER SOUTH FACE OF SOUTH WALL WITH 5/8" TYPE X; OK TO COVER SOUTH FACE OF SOUTH WALL WITH 2ND LAYER 5/8" TYPE X; OK TO INSTALL 1ST LAYER 5/8" TYPE X GWB AT CEILING;
---	------	--

Comments: