



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20162628	Date:	April 17, 2017
Project Title:	KAY JEWELERS	Applicant:	
Location:	820 NW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64086	ALLIANCE FIRE PROTECTION LLC 130 W 9TH AVE STE 101 KANSAS CITY, MO 64116	
Type of Work:			
Occupancy Group:	M		
Description:	NEW TENANT FINISH FOR JEWELRY SALES	Primary: (913) 888-0647	
Construction Type:	Type IIB (Unprotected)		
Map Page:	195A		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. ACTION REQUIRED:(verified at inspection)

All flow switches and tamper valves for this suites system shall have a posted address at the tamper valve, the address shall be readable from floor level.

2. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(verified at inspection)

Testing of the flow switch and tamper valve will be required priot to the final occupancy inspection. The fire alarm panel shall recieve a signal from each device.

3. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

ACTION REQUIRED:(verifiied at inspection)

The systems riser shall be current with all required testing, service, maintenance. A current service tag shall be posted on the systems riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.