



**LEE'S SUMMIT**  
**MISSOURI**



---

**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20170501	Date:	April 17, 2017
Project Title:	BRAIN BALANCE LEE'S SUMMIT	Applicant:	
Location:	413 NW MURRAY RD, LEES SUMMIT, MO 64081		
Type of Work:			FIRE & SECURITY SOLUTIONS
Occupancy Group:			6025 Martwy, Suite 104 Mission, Kansas 66202
Description:	COMMERCIAL TENANT		
FINISH			
Construction Type:	Not Applicable		<NO CONTACT NAME AVAILABLE>
Map Page:	195E		<NO CONTACT INFORMATION AVAILABLE>

FIRE & SECURITY SOLUTIONS GROUP INC  
6025 MARTWAY STE 104  
MISSION, KS 66202

Primary: (913) 789-7160

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Alarm Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

**ACTION REQUIRED:**

Acceptance testing of the alarm systems activation and notification devices will be required prior to the final occupancy inspection. To schedule a test contact the fire department at 816-969-1300

**2. ACTION REQUIRED:(verified at inspection)**

A smoke detector needs to be installed above the new NAC panel.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**