

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20162083, Public Works Infrastructure Permit - Commercial

WATER UTILITIES FACILITY

Address: 1200 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Backflow Preventer and Vault Informational	Brice Lawson	Partial	Monday, April 17, 2017
1	Brice Lawson 04/17/2017 2:12 PM She Digs It submitted the backflow preventer test data sheet for the 6" backflow preventer.		

PW-Water Line - Coliform Test 1 Informational	Brice Lawson	Partial	Monday, April 17, 2017
1	Brice Lawson 04/17/2017 2:06 PM She Digs It flushed the domestic water from the ends of the 4", 1", 1.5" and the 6" line at the backflow preventer for approx. 10 min.		

She Digs It chlorinated the 4" domestic waterline from the Tee fitting at the 8" main to the riser in the building. They chlorinated the 6" water line from the construction tap just south of the 8" Tee fitting to the backflow preventer. They chlorinated the 1" copper water line from the 4" domestic line to the location where it is stubbed into the building. They chlorinated the 1.5" copper water line from the 4" line over the west opening on the water meter for the irrigation line.

Comments: