

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162575, Building Permit - Residential
Address: 304 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Failed	Tuesday, April 18, 2017

Corrective Action Required

1	Misc	DO NOT COVER UNTIL GAS PRESSURE CAN HOLD AND TEST IS APPROVED.
---	------	--

Gas Service Inspection - Residential	Mike Copeland	Failed	Tuesday, April 18, 2017
---	---------------	--------	-------------------------

Corrective Action Required

1	Misc	-PRESSURE IS BELOW TEN PSI (~5). FIX LEAKAGE AND RETEST
---	------	---

Comments: