

Inspection Summary

Permit #: PRCOM20152438, Building Permit - Commercial
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Tuesday, April 18, 2017

Corrective Action Required

1 Misc

RESOLVE ANY ISSUES WITH:
- WATER UTILITIES DEPT
- PUBLIC WORKS

Corrective Action Required

3 Misc

NEC 600.4 ELECTRIC SIGN MARKINGS: SIGNS AND OUTSIDE LIGHTING SYSTEMS SHALL BE SHOP-LABELED WITH LISTING, **MANUFACTURER'S NAME, TRADEMARK, OR OTHER MEANS OF IDENTIFICATION; AND INPUT VOLTAGE AND CURRENT RATING.**

Corrective Action Required

4 Misc

GLAZING IN HAZARDOUS LOCATIONS: TO BE RE-INSPECTED FOR LABELING AFTER GLASS IS FULLY CLEANED

Corrective Action Required

5 Misc

OCCUPANCY STATUS: OK TO SET UP FOR OPERATION. STAFF, FURNISHING, AND CONTENTS OK. NO OPERATION, GATHERINGS, OR SERVICES PRIOR TO APPROVAL.

Corrective Action Required

6 Misc

IPC 608: BACKFLOW PREVENTION DEVICE REQUIRED AT POTABLE WATER-PIPED EQUIPMENT EXCEPT WHERE APPROVED AIR GAP IS EXPOSED. e.g. PIPED COFFEE/TEA MAKERS IF INSTALLED

Occupancy Inspection - Fire	Michael Weissenbach	Passed	Tuesday, April 18, 2017
------------------------------------	---------------------	--------	-------------------------

Alarm Test	Michael Weissenbach	Passed	Tuesday, April 18, 2017
-------------------	---------------------	--------	-------------------------

Comments: