

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161178, Building Permit - Commercial
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Tuesday, April 18, 2017

Partial Correction

1 Misc

NO ISSUES FOUND WITH PVC CONDUIT TO BE CAST INTO POUR OF ENTRY SLAB AT VESTIBULE 101

PVC CONDUIT IN PLACE BEYOND THE PREP FOR SLAB POUR WILL NEED TO BE PROTECTED IF NOT =>18" BELOW FINAL GRADE

Comments: