

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162366, Building Permit - Commercial
Address: 825 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|---------------------------|
| Underground Electrical Inspection - Commercial | John Borns | Partial | Wednesday, April 19, 2017 |

Partial Correction

| | | |
|---|------|--|
| 1 | Misc | OK TO COVER WHEN READY PVC CONDUIT TRENCHED BETWEEN APARTMENT BUILDING AND DETACHED GARAGES: ONE 1-1/4" FROM BUILDING TO BUILDING + ONE 3/4" FROM GARAGE TO MIDWAY BETWEEN BUILDINGS STUBBED UP FOR FUTURE EXTENSION FOR SITE LIGHTING |
|---|------|--|

Partial Correction

| | | |
|---|------|--|
| 2 | Misc | OK TO COVER WHEN READY THREE 3" PVC SECONDARY SERVICE CONDUITS FROM TRANSFORMER LOCATION AT SE CORNER OF BLDG #6 TO BLDG ENTRY AT E END OF BLDG #6 |
|---|------|--|

Comments: