

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20162575, Building Permit - Residential  
Address: 304 SE MILL CREEK DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mike Copeland	Failed	Thursday, April 20, 2017

Corrective Action Required

1	Misc	DO NOT COVER UNTIL GAS PRESSURE CAN HOLD AND TEST IS APPROVED.
---	------	--

<b>Gas Service Inspection - Residential</b>	Mark Harding	Failed	Thursday, April 20, 2017
---	--------------	--------	--------------------------

Corrective Action Required

1	Misc	-PRESSURE IS BELOW TEN PSI (~5). FIX LEAKAGE AND RETEST
---	------	---

4/20-  
4lbs psi, valve 1/2 open at fireplace, no protection at fireplace wall to protect wardflex.

**Comments:**