

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20162048, Building Permit - Commercial
Address: 820 NW BLUE PKWY, Unit:H, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Thursday, April 20, 2017

Partial Correction
1 Misc

OK TO COVER WHEN READY LIGHT-GAUGE STEEL FRAMING FOR SOFFITS/BULKHEADS AT: MEN'S APPAREL 001;

LIGHT COVES AT MEN'S H&M, LADIES EAST OF (C);

Partial Correction
2 Misc

OKAY TO COVER GWB CEILING FRAMING & ABOVE-CEILING SYSTEMS AT: BABY/BOY/GIRL FLOOR AREA; MEN'S H&M; **LADIES EVERYDAY EXCEPT NW ENTRANCE CORNER -- AFTER REMAINING HVAC DUCT & DUCT INSULATION IS COMPLETED; FITTING RM AREA 2 (MEN'S);**

All Rough Inspection - Commercial	John Borns	Partial	Thursday, April 20, 2017
--	------------	---------	--------------------------

Partial Correction
1 Misc

OK TO COVER WHEN READY FRAMING AND ELECTRICAL WIRING AT PLATFORMS AT: DISPLAY WINDOW #3; POSTER WINDOW #5; DISPLAY WINDOW #1; POSTER WINDOW #1;

Comments:

