

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20162298, Building Permit - Residential

Address: 3913 NE TROON DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Steve Robbins	Passed	Thursday, April 20, 2017

Informational

- 1 I was in the area doing another inspection and was asked to look at this sidewalk and ada ramp. They formed everything and had the rock compacted. I came back the next day to check and I passed it. The sanitary MH was in the path of the sidewalk and was too low, so I had them raise it and it was a little high , but after trying to adjust it I let them leave it a little high.Steve Robbins 04/20/2017 4:03 PM

Comments: