

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit: PRRES20162559, Building Permit - Residential
Address: 1344 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Bart Reese	Passed	April 21, 2017

Comments: Inspected forms - depth provided by the forms was acceptable.