

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162366, Building Permit - Commercial
Address: 825 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Friday, April 21, 2017

Partial Correction

1	Misc	OK TO COVER WHEN READY PVC CONDUIT TRENCHED BETWEEN APARTMENT BUILDING AND DETACHED GARAGES: ONE 1-1/4" FROM BUILDING TO BUILDING + ONE 3/4" FROM GARAGE TO MIDWAY BETWEEN BUILDINGS STUBBED UP FOR FUTURE EXTENSION FOR SITE LIGHTING
---	------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Partial Correction

2	Misc	OK TO COVER WHEN READY THREE 3" PVC SECONDARY SERVICE CONDUITS FROM TRANSFORMER LOCATION AT SE CORNER OF BLDG #6 TO BLDG ENTRY AT E END OF BLDG #6; FROM TRANSFORMER LOCATION AT WEST END OF BLDG #6 TO BLDG ENTRY AT WEST END
---	------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: