

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20170233, Building Permit - Commercial  
Address: 930 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Monday, April 24, 2017

Partial Correction

1 Misc

ABOVE-CEILING OK BELOW:

-HARD-LID CEILING AT LOBBY, CORRIDOR, AND RESTROOMS

Corrective Action Required

2 Misc

**ACT ABOVE-CEILING NOT READY FOR INSPECTION. SPRINKLER HEADS NOT IN PLACE,**

**Comments:**