

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20162545  
**Address:** 1357 NE BRANDYWINE RD, LEES SUMMIT, MO 64064  
**Inspected On:** Monday, April 24, 2017  
**Inspected By:** Khanh Nguyen  
**Expiration Date:** 5/24/2017 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Temporary C of O	Monday, April 24, 2017

Corrective Action Required:

- |   |      |   |
|---|------|---|
| 1 | Misc | -FINAL GRADE, SOD, SPLASHBLOCKS   |
|   |      | -BLOCK BASEMENT DOOR STUD PER SECURITY CODE   |
|   |      | **BLOCK AT STRIKE PLATE HEIGHT TO COLUMN, THEN<br>COUNTER-BLOCK ON THE OTHER SIDE OF COLUMN |
|   |      | -DECK DOOR-INSTALL 4-3" SCREWS AT STRIKE PLATE  |