

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162987, Building Permit - Residential

Address: 2102 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822104 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822106 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822100 SW TIMBERTRACE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Monday, April 24, 2017

Corrective Action Required

1	Misc	2100 2102 JOIST HANGERS IN KITCHEN. - REPAIR ROCK OVER STAIRS AT ROOF. - SCAB 2X4 ON EACH SIDE OF 2X6 OVER MSTR BATH WHERE NOTCHED. 2104 INSTALL STUD BEHIND PANEL JOIST HANGERS IN KITCHEN -2102-4 REPAIR ROCK OVER ATTIC ACCESS IN GARAGE AT ROOF 2106 RE-ROUTE BATH VENT -SUPPORT FLAT 2X4 FOR JOST JOIST IN BATHROOM. OK TO INSULATE
---	------	---

Electrical Service Inspection - Residential	Mark Harding	Passed	Monday, April 24, 2017
--	--------------	--------	------------------------

Rated Assembly Inspection	Mark Harding	Failed	Monday, April 24, 2017
----------------------------------	--------------	--------	------------------------

Comments: