

Brandon Carr

Report Email: bcarr@shedigsit.com

Copy Email:

Lab Report Fax No:

Lab Report Contact 1: (816) 809-2638

Lab Report Contact 2:

Customer ID No: 8672

Customer PO No:

Collected By: Client

Invoice No: 37401

She Digs It
 3424 W. Duncan Rd.

Blue Springs, MO 64015

Report of Analysis

Laboratory Report ID No:

16448

Project Name:

Item No.	Cat NO	ANALYSIS	COLLECTED	ANALYZED	REPORTING LIMIT	RESULTS
	Line NO	SAMPLE TYPE	SAMPLE SITE NOTES		TEST METHOD	
1	6191	Bacteria, P/A E. Coli	4/20/17	4/20/17	1	ABSENT
	94713		BACKFLOW PREV. DAY 1-A		SM9223 B	
2	6191	Bacteria, P/A E. Coli	4/20/17	4/20/17	1	ABSENT
	94714		WASH BAY DAY 1-A		SM9223 B	
3	6191	Bacteria, P/A E. Coli	4/20/17	4/20/17	1	ABSENT
	94716		4" BLDG RISER DAY 1-A		SM9223 B	
4	6191	Bacteria, P/A E. Coli	4/20/17	4/20/17	1	ABSENT
	94718		METER PIT DAY 1-A		SM9223 B	
5	6191	Bacteria, P/A E. Coli	4/21/17	4/21/17	1	ABSENT
	94725		BACKFLOW PREV. DAY 2-A		SM9223 B	
6	6191	Bacteria, P/A E. Coli	4/21/17	4/21/17	1	ABSENT
	94726		WASH BAY DAY 2-A		SM9223 B	
7	6191	Bacteria, P/A E. Coli	4/21/17	4/21/17	1	ABSENT
	94728		4" BLDG RISER DAY 2-A		SM9223 B	
8	6191	Bacteria, P/A E. Coli	4/21/17	4/21/17	1	ABSENT
	94730		METER PIT DAY 2-A		SM9223 B	
9	6190	Bacteria, P/A T. Coliform	4/20/17	4/20/17	1	ABSENT
	94712		BACKFLOW PREV. DAY 1-A		SM9223 B	
10	6190	Bacteria, P/A T. Coliform	4/20/17	4/20/17	1	ABSENT
	94715		WASH BAY DAY 1-A		SM9223 B	

Comments, if present, concern this Lab Work Order:

Chlorine analysis exceeded holding time for all samples.

The reported analytical results relate only to the sample submitted.

This report shall not be reproduced, except in full, without written approval by Blue Valley Laboratories, Inc.

Blue Valley Laboratories, Inc.

Report For: She Digs It

Report of Analysis

Report ID No: **16448**

Item No.	Cat NO	ANALYSIS	COLLECTED	ANALYZED	REPORTING LIMIT	RESULTS
	Line NO	SAMPLE TYPE	SAMPLE SITE NOTES		TEST METHOD	
11	6190	Bacteria, P/A T. Coliform	4/20/17	4/20/17	1	ABSENT
	94717		4" BLDG RISER DAY 1-A		SM9223 B	
12	6190	Bacteria, P/A T. Coliform	4/20/17	4/20/17	1	ABSENT
	94719		METER PIT DAY 1-A		SM9223 B	
13	6190	Bacteria, P/A T. Coliform	4/21/17	4/21/17	1	ABSENT
	94724		BACKFLOW PREV. DAY 2-A		SM9223 B	
14	6190	Bacteria, P/A T. Coliform	4/21/17	4/21/17	1	ABSENT
	94727		WASH BAY DAY 2-A		SM9223 B	
15	6190	Bacteria, P/A T. Coliform	4/21/17	4/21/17	1	ABSENT
	94729		4" BLDG RISER DAY 2-A		SM9223 B	
16	6190	Bacteria, P/A T. Coliform	4/21/17	4/21/17	1	ABSENT
	94731		METER PIT DAY 2-A		SM9223 B	
17	6332	Chlorine, Total Residual	4/20/17	4/20/17	.13 mg/L	2.1
	94720		4" BLDG RISER DAY 1-A		Hach 8167	
18	6332	Chlorine, Total Residual	4/20/17	4/20/17	.26 mg/L	2.2
	94721		METER PIT DAY 1-A		Hach 8167	
19	6332	Chlorine, Total Residual	4/20/17	4/20/17	.26 mg/L	2.1
	94722		WASH BAY DAY 1-A		Hach 8167	
20	6332	Chlorine, Total Residual	4/20/17	4/20/17	.26 mg/L	2.2
	94723		BACKFLOW PREV. DAY 1-A		Hach 8167	
21	6332	Chlorine, Total Residual	4/21/17	4/21/17	.26 mg/L	2.1
	94803		4" BLDG RISER DAY 2-A		Hach 8167	
22	6332	Chlorine, Total Residual	4/21/17	4/21/17	.26 mg/L	2.1
	94804		METER PIT DAY 2-A		Hach 8167	
23	6332	Chlorine, Total Residual	4/21/17	4/21/17	.26 mg/L	1.7
	94805		WASH BAY DAY 2-A		Hach 8167	
24	6332	Chlorine, Total Residual	4/21/17	4/21/17	.26 mg/L	2.1
	94806		BACKFLOW PREV. DAY 2-A		Hach 8167	
25	6420	Weekend Testing (Sat)			0	FEE
	94732					