

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20162982, Building Permit - Residential

Address: 2112 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822114 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822116 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822110 SW TIMBERTRACE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Sidewalk Inspection	John DiMauro	Passed	Tuesday, April 25, 2017

Informational

- 1 John DiMauro 04/25/2017 11:15 AM
Mitch Plemmons informed me that he inspected the pre pour sub grade. The cross slope of the sidewalk was less than 2.0%.

Driveway Inspection	John DiMauro	Passed	Tuesday, April 25, 2017
---------------------	--------------	--------	----------------------------

Informational

- 1 John DiMauro 04/25/2017 11:10 AM
Mitch Plemmons informed me that he inspected the pre pour sub grade. The driveway approach cross slope was less than 2.0%.

Comments: