

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20151744, Building Permit - Commercial
Address: 2640 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Khanh Nguyen	Partial	Wednesday, April 26, 2017

Partial Correction

1 Misc

4 4" CONDUITS FROM TRANSFORMER TO GEAR AT WEST SIDE OF BUILDING APPROVED.

-LIGHT POLE PIER AT SOUTH SIDE OF BUILDING-OK

Comments: