

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20170197, Building Permit - Residential

Address: 2223 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822225 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822227 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822221 SW BURNINGWOOD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Mark Harding	Failed	Wednesday, April 26, 2017

Corrective Action Required

1	Misc	failed- provide approved plans piers need to be 12" deep. lap rebar 24" provide 8" deep grade beam install chairs
---	------	---

Comments: