

## **CODES ADMINISTRATION**

## **Inspection Summary**

Permit #: PRCOM20162931, Building Permit - Commercial Address: 1748 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - John Borns Partial Wednesday, April 26, 2017

**Codes Commercial** 

Corrective Action Required

1 Misc IDENTITY/LABEL MAIN DISCONNECT FOR ELECTRICAL POWER

Corrective Action Required

2 Misc ENSURE GAS SERVICE IS LABELED

**Corrective Action Required** 

3 Misc LABEL ELECTRICAL PANEL LP6

Corrective Action Required

4 Misc AFFIX ACCESSIBLE RESTROOM SIGNS

Corrective Action Required

5 Misc ELECTRICAL FLOOR BOXES TO BE INSTALLED AT THERAPY ROOMS

112 & 113

**Corrective Action Required** 

6 Misc OK TO SET UP FOR BUSINESS

Occupancy Inspection - Michael Passed Wednesday, April 26, 2017

Fire Weissenbach

**Comments:**