

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162363, Building Permit - Commercial
Address: 805 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Wednesday, April 26, 2017

Partial Correction

1 Misc

NO MATERIAL OR WORKMANSHIP ISSUES FOUND ON
DATACOMM CONDUITS RUN FROM FOOTING ELEVATION UP
OUTSIDE OF BUILDING WEST FOUNDATION WALL -- THREE 3";
TWO 1-1/4"; ONE 3/4"

Partial Correction

2 Misc

OK TO COVER WHEN READY SECONDARY SERVICE CONDUITS
FROM TRANSFORMER LOCATION AT NE CORNER OF BLDG #2 TO
BLDG ENTRY AT SW CORNER OF BLDG #3; **THREE 3" FROM
XFRMR LOC @ S END OF #7 SOUTH TO N END OF #3;**

Comments: