

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20170898, Building Permit - Commercial
Address: 196 NW OLDHAM PKWY, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Wednesday, April 26, 2017

Corrective Action Required		
1 Misc	AFFIX ACCESSIBLE RESTROOM SIGN AT DOOR	
Corrective Action Required		
2 Misc	ANSI 603.3 MOUNTING OF MIRRORS AT ACCESSIBLE RESTROOMS: SET BOTTOM OF VIEWING SURFACE <= 40" AFF	
Corrective Action Required		
3 Misc	ELECT RECPTS REQUIRED AT SERVICE COUNTER	
Corrective Action Required		
4 Misc	EXTERIOR LIGHTED SIGN SUBJECT TO APPROVAL	
Corrective Action Required		
5 Misc	OK TO SET UP FOR BUSINESS	

Above Ceiling Inspection	John Borns	Passed	Wednesday, April 26, 2017
---------------------------------	------------	--------	---------------------------

Occupancy Inspection - Fire	Michael Weissenbach	Passed	Wednesday, April 26, 2017
------------------------------------	---------------------	--------	---------------------------

In-wall Inspection	Mark Harding	Passed	Wednesday, April 26, 2017
---------------------------	--------------	--------	---------------------------

Comments:

