

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162363, Building Permit - Commercial  
Address: 805 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	John Borns	Partial	Thursday, April 27, 2017

Partial Correction

1	Misc	OK TO POUR WHEN READY PERIMETER FOOTING & INTEGRAL COLUMN FOOTINGS AT LOWER BLDG N, E, & S. NO UFER JUMPERS INSTALLED IN THESE SECTIONS.
		<b>OK TO POUR WHEN READY PERIMETER FOOTING &amp; INTEGRAL COLUMN FOOTINGS AT <u>UPPER</u> BLDG N, W, &amp; S. UFER JUMPERS INSTALLED AT N &amp; S ENDS.</b>
		12/30-OK THE ELEVATOR SLAB
Partial Correction		
2	Misc	OK TO POUR POST-TENSIONED FLOOR SLAB SYSTEM AS APPROVED BY SPECIAL INSPECTOR
Partial Correction		
3	Misc	OK TO POUR WHEN READY RETAINING WALL FOOTINGS AT SW & NW
Partial Correction		
4	Misc	OK TO POUR WHEN READY TRENCH FOOTINGS AT BOTH DETACHED GARAGES. ENSURE MIN 3" RE-BAR CLEARANCE TO BOTTOMS AND BANKS DURING POUR.

**Comments:**