

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20162811, Building Permit - Commercial
Address: 860 NW BLUE PKWY, Unit:W, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Thursday, April 27, 2017

Corrective Action Required

1	Misc	HANDRAILS REQUIRED AT STAIRS AT DINING PLATFORM
---	------	---

Corrective Action Required

2	Misc	IPC 608: BACKFLOW PREVENTION DEVICE REQUIRED AT POTABLE WATER-FED EQUIPMENT EXCEPT WHERE APPROVED AIR GAP IS EXPOSED. AT CARBONATED BEVERAGE DISPENSING EQUIPMENT USE ASSE 1022 LISTED DEVICE.
---	------	--

Corrective Action Required

3	Misc	LABEL DUAL GAS AND ELECTRICAL SERVICES
---	------	--

Corrective Action Required

4	Misc	LABEL RTU'S AND REFLECT DESIGNATIONS AT ELECTRICAL PANELS
---	------	---

Corrective Action Required

5	Misc	IMC 507.16 COMMERCIAL KITCHEN GREASE HOOD PERFORMANCE TEST: NEBB-CERTIFIED REPORT REQUIRED TO BE SUBMITTED TO INSPECTOR WHEN EQUIPMENT IS OPERATIONAL AND BEFORE COMMERCIAL USE. SMOKE CAPTURE TEST TO BE CERTIFIED BY 3RD PARTY OR WITNESSED BY INSPECTOR BEFORE ANY USE IS APPROVED.
---	------	--

Occupancy Inspection - Fire	Michael Weissenbach	Temporary C of O	Thursday, April 27, 2017
------------------------------------	---------------------	------------------	--------------------------

Comments: