



**LEE'S SUMMIT**  
MISSOURI



**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No: PRCOM20160939 Date: April 28, 2017  
Project Title: WILSHIRE AT LAKEWOOD Applicant:  
MEMORY CARE  
Location: ALL SAFE FIRE PROTECTION LLC  
3320 NE WILSHIRE DR, LEES 8113 N OAK TRFWY STE D  
SUMMIT, MO 64064 KANSAS CITY, MO 64118  
Type of Work: Primary: (816) 492-7202  
Occupancy Group: I-1  
Description: NEW MEMORY CARE  
FACILITY WITH FULL  
COMMERCIAL KITCHEN  
Construction Type: Type VA (1 hour)  
Map Page: 175L

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Sprinkler Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

**1. AIR LINES**

**ACTION REQUIRED:(verified at inspection)**

all air lines from the air compressor leading to the dry system riser shall be ridged pipe or tubing. No hoses.

2. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**