

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162985, Building Permit - Residential

Address: 2092 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822094 SW TIMBERTRACE LN, LEES
SUMMIT, MO 640822096 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822090 SW
TIMBERTRACE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Monday, May 01, 2017

Corrective Action Required

1	Misc	connect all bath fans
		install stud under LVL 2902 closet wall mstr 1st floor
		install joist hangers for 2x10s 1st floors

Rated Assembly Inspection	Mark Harding	Passed	Monday, May 01, 2017
----------------------------------	--------------	--------	----------------------

Erosion Control	Mark Harding	Failed	Monday, May 01, 2017
------------------------	--------------	--------	----------------------

Electrical Service Inspection - Residential	Mark Harding	Passed	Monday, May 01, 2017
--	--------------	--------	----------------------

Comments: