

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, May 01, 2017

Partial Correction
1 Misc

SEPARATION WALL @ (6)/(7):

LEVEL TWO:

ON (6) EAST FINISH FACE 2ND LAYER FROM (Q) TO (Z);

Partial Correction
2 Misc

PENTHOUSE D EAST WALL OK TO COVER WHEN READY: FRAMING & LINER BOARD; **ONE LAYER 5/8" TYPE X;**

In-wall Inspection	John Borns	Partial	Monday, May 01, 2017
---------------------------	------------	---------	----------------------

Partial Correction
1 Misc

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING 2ND FLOOR LOCATIONS:
A218; C271; AREA "A"; AREA "C" N OF STAIR; C202; C203; C206;
C207; B209; B258A; C218; C205; 202; 203;

AREA "D": B257; B257A; B257B; B258; B261; ALL NORTH OF (G)
INCLUDING 254, 256, 257;

BETWEEN COMMONS A-C EXCEPT 202,3,6,9,18.

2-250; 2-251; 2-252; 4-201; 4-201A; 4-202; 4-203; 2-204/205;
2-206; WEST WYTHE ON (6) FROM (R) TO (Z) OK TO HANG 1ST
LAYER 5/8" TYPE X; B201 EXCEPT @ DOOR 2-201; B202; B203;
B207; B210;

Partial Correction

2 Misc OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING 1ST FLOOR LOCATIONS: EAST WALL OF ELECT 3-161; OK TO 4' TOP-OUT WALLS;

AREA "A" COMPLETE

AREA "B": B101 S,W,N WALLS; B102; 103; 104; 105; 106; 107; 108; 109; 110; 111; 152; 153; 153A; 153B; 154; 155; 156-161;

AREA "C" COMPLETE EXCEPT C160; B153; D161; B209; B258A;

AREA "D": D150/151/152 NORTH & WEST WALLS; 150A; 151A; 152A; 153; 154; 155; 159; 160; 162; D156; D157; D102; D103; 4-151A, D154A, D154B FULL HEIGHT; D101; B150 N&E; B151 N&W;

*: EAST WALL TO 12' AFF ONLY

Partial Correction
3 Misc

OK TO COVER WHEN READY FRAMING & ENCLOSED SYSTEMS AT KNEEWALLS AT: 1-101; 1-117; 3-250;

**Above Ceiling
Inspection**

John Borns

Partial

Monday, May 01, 2017

Partial Correction
1 Misc

OK TO COVER WHEN READY GWB CEILING /SOFFIT /LIGHT COVE FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING 1ST FLOOR SPACES: VESTIBULE @ MEN'S & WOMEN'S RESTROOMS 102 / 103; SOFFITS/FACIAS @ C104 LAB, 1-101, 1-117, 1-118; LIGHT COVE @ 1-151; HARD LID SOFFIT FIRST FLOOR AREA C A156; RR'S 102 & 103; A202; C202; C250; 206; 259; TENSION STUDS AT LIGHT SLOT CEILING AT N.2/9.3; BULKHEAD AT B152 E&S; HARD LID SOFFIT TENSION STUDS @ 4-150/151 & 152; BULKHEADS @ 4-101, 102, 103; SOFFIT AT CORRIDOR B155 EAST SIDE; **TENSION STUDS SUPPORTING SOFFITS AT B151, B152;**

Comments: