

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20170233, Building Permit - Commercial
Address: 930 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Failed	Monday, May 01, 2017

Corrective Action Required

2 Misc

REMOVE ALL TEMPORARY ELECTRIC WIRING

Corrective Action Required

3 Misc

UNTERMINATED MC ELECTRICAL CABLE ABOVE #3. REMOVE
BACK TO SOURCE BOX.

Corrective Action Required

4 Misc

DRAWING ME-2.1:

- RETURN AIR BOOTS PER DETAIL NOT FOUND INSTALLED.
- SCREW CLAMPS ON FLEX DUCT CONNECTIONS NOT FOUND TO
BE INSTALLED.

Comments: