

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161179, Building Permit - Commercial
Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Failed	Tuesday, May 02, 2017

Corrective Action Required

1	Misc	NO APPROVED ELECTRICAL RISER DRAWING FOR THIS BUILDING
---	------	---

Above Ceiling Inspection	John Borns	Partial	Tuesday, May 02, 2017
-------------------------------------	------------	---------	-----------------------

Partial Correction

2	Misc	OK TO COVER WHEN READY FRAMING AND SYSTEMS TO BE CONCEALED AT INTERMITTANT GWB DROPPED CEILING SEGMENTS IN MAIN CORRIDORS AT 3RD, 2ND AND 1ST FLOORS
---	------	--

CEILING AREAS AT ELEVATOR LOBBIES NOT READY FOR INSPECTION

Partial Correction

3	Misc	OK TO COVER WHEN READY CEILING FRAMING & ABOVE-CEILING SYSTEMS AT: B118; B119;
---	------	---

Comments: