

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Wednesday, May 03, 2017

Partial Correction
1 Misc

SEPARATION WALL @ (6)/(7):

LEVEL TWO:
ON (6) EAST FINISH FACE 2ND LAYER FROM (Q) TO (Z);

Partial Correction
2 Misc

PENTHOUSE D EAST WALL OK TO COVER WHEN READY: FRAMING & LINER BOARD; **TWO LAYERS 5/8" TYPE X OK TO TAPE & MUD -- FIRE-STOPPED**

Above Ceiling Inspection	John Borns	Partial	Wednesday, May 03, 2017
---------------------------------	------------	---------	-------------------------

Partial Correction
1 Misc

OK TO COVER WHEN READY GWB CEILING /SOFFIT /LIGHT COVE FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING 1ST FLOOR SPACES: VESTIBULE @ MEN'S & WOMEN'S RESTROOMS 102 / 103; SOFFITS/FACIAS @ C104 LAB, 1-101, 1-117, 1-118; LIGHT COVE @ 1-151; HARD LID SOFFIT FIRST FLOOR AREA C A156; RR'S 102 & 103; A202; C202; C250; 206; 259; TENSION STUDS AT LIGHT SLOT CEILING AT N.2/9.3; BULKHEAD AT B152 E&S; HARD LID SOFFIT TENSION STUDS @ 4-150/151 & 152; BULKHEADS @ 4-101, 102, 103; SOFFIT AT CORRIDOR B155 EAST SIDE; TENSION STUDS SUPPORTING SOFFITS AT B151, B152; **ROLLER SHADE POCKETS AT "C" A252 AND AT "A" A201; SOFFIT @ 3-250; SOFFIT + EYEBROW @ 205 INTNL STUDIES;**

Comments: