

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161179, Building Permit - Commercial  
Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Failed	Wednesday, May 03, 2017

Corrective Action Required  
5 Misc

RAIN WATER IS SATURATING 5/8" TYPE X GWB AT WALLS AND  
CEILINGS AT B118 & B119. NOT APPROVED TO TAPE & MUD.  
REMOVE AND REPLACE ANY SATURATED GWB.

<b>Electrical Service Inspection - Commercial</b>	John Borns	Passed	Wednesday, May 03, 2017
---	------------	--------	-------------------------

**Comments: RELEASE ELECTRICAL SERVICE.**