

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20152912, Building Permit - Commercial  
Address: 2751 NE DOUGLAS ST, Unit:T, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	Khanh Nguyen	Passed	Wednesday, May 03, 2017

<b>In-wall Inspection</b>	Khanh Nguyen	Partial	Wednesday, May 03, 2017
---------------------------	--------------	---------	-------------------------

Corrective Action Required

1	Misc	-INSTALL BLOCKINGS FOR GRAB BARS PER ANSI 117 **MAKE SURE TO HAVE THE BLOCKING FOR THE REAR GRAB BAR, AS WELL AS THE 18" VERTICAL GRAB BAR **OK TO ROCK
---	------	--

**Comments:**