

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20161966, Building Permit - Residential  
Address: 312 SE MILL CREEK DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mike Copeland	Failed	Wednesday, May 03, 2017

### Corrective Action Required

1	Misc	-INSTALL FINAL GRADE, SOD, SPLASHBLOCKS -CHECK NAMEPLATE RATING OF AC AT LATER INSPECTION, 50 AMP BREAKER INSTALLED. -PART OF THE DECK IS ATTACHED TO A CANTILEVERED PORTION OF THE HOUSE. -INSTALL SECURITY SCREWS REAR DOOR. -FIRE PROTECT FLOORS IN UNFINISHED AREAS
---	------	---

### Comments: