

Inspection Summary

Permit #: PRCOM20151897, Building Permit - Commercial
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Commercial	John Borns	Passed	Thursday, May 04, 2017

Comments: POOL LIGHT NICHE BONDING CONDUCTOR TERMINATED IN SHELL AND COATED WITH POTTING COMPOUND.