

Certificate of Occupancy

Permit #: PRCOM20170233
Address: 930 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086
Inspected On: Thursday, May 04, 2017
Inspected By: John Borns

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - John Borns Codes Commercial	Full C of O		Thursday, May 04, 2017

Comments: ALL ELECTRICAL RECEPTACLES TO BE MADE SOLID TO BOX.