

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20152150, Public Works Infrastructure Permit - Commercial
I-470 BUSINESS AND TECHNOLOGY CENTER
Address: 2640 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Sanitary Sewer - Manhole Adjustment Informational	Tom Chandler	Passed	Thursday, May 04, 2017
1	Tom Chandler 05/04/2017 3:12 PM Added a 36" barrel section to existing Manhole 14-025. Wrapped and Backfilled. There is a fiber optic line running right along the southwest of the manhole base. Evidence of bore hitting cone section of the manhole as well.		

Comments: